

NOTES:

- 1. THE BASE MAY BE OMITTED UNDER SIDEWALK IF SUBGRADE IS SANDY SOIL AND WHEN AUTHORIZED BY THE PUBLIC WORKS INSPECTOR.
- 2. TYPICAL MAY VARY 0.5% MIN. TO 2.0% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
- 3. TYPICAL MAY VARY 1% MIN. TO 4.0% MAX TO MATCH EXISTING CONDITONS AND TO FACILITATE JOINS.
- 4. THICKNESS OF BASE REQUIRED UNDER CURB & GUTTER SHALL BE 8".
- 5. CURB AND GUTTER AS PER SPPWC STANDARD 120 TYPE A2 UNLESS OTHERWISE NOTED.
- 6. SIDEWALK NOT TO BE PLACED MONOLITHICALLY WITH CURB.

CITY OF TORRANCE		
DATE ISSUED	TYPICAL SECTION	STANDARD NO.
DEC 2012	LOCAL STREET	T102
	ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737	SHEET 1 OF 1