



COLLECTOR

NOTES:

1. THE BASE MAY BE OMITTED UNDER SIDEWALK IF SUBGRADE IS SANDY SOIL AND WHEN AUTHORIZED BY THE PUBLIC WORKS INSPECTOR.
2. TYPICAL - MAY VARY 0.5% MIN. TO 2% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
3. TYPICAL - MAY VARY 1% MIN. TO 4.0% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
4. THICKNESS OF BASE REQUIRED UNDER CURB & GUTTER SHALL BE 8".
5. IF SIDEWALK IS ADJACENT TO CURB, SIDEWALK WIDTH SHALL BE 5' MINIMUM AND HAVE 4' CLEAR AROUND ANY OBSTRUCTION. ALSO SEE T108 AND T109.
6. CURB AND GUTTER AS PER SPPWC STANDARD 120 TYPE A2 UNLESS OTHERWISE NOTED.

CITY OF TORRANCE

DATE ISSUED	TYPICAL SECTION	STANDARD NO.
DEC 2012	COLLECTOR AND ARTERIAL STREET	T103
	ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737 <div style="float: right; text-align: right;"> </div>	SHEET 1 OF 2

TT/T103-1