



## MINOR AND MAJOR ARTERIAL

### NOTES:

1. THE BASE MAY BE OMITTED UNDER SIDEWALK IF SUBGRADE IS SANDY SOIL AND WHEN AUTHORIZED BY THE PUBLIC WORKS INSPECTOR.
2. TYPICAL - MAY VARY 0.5% MIN. TO 2% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
3. TYPICAL - MAY VARY 1% MIN. TO 4.0% MAX TO MATCH EXISTING CONDITIONS AND TO FACILITATE JOINS.
4. THICKNESS OF BASE REQUIRED UNDER CURB & GUTTER SHALL BE 8".
5. CURB AND GUTTER AS PER SPPWC STANDARD 120 TYPE A2 UNLESS OTHERWISE NOTED.
6. IN CLAY SOILS, EITHER LIME TREAT THE SUBGRADE OR INSTALL GEOTEXTILE MEMBRANE OVER SUBGRADE AND PLACE 12" OF CRUSHED AGGREGATE BASE ON MEMBRANE. GEOTEXTILE MEMBRANE SHALL BE NON-WOVEN AND MEET THE REQUIREMENTS FOR TYPE 250N PER GREEN BOOK SECTION 213-2 GEOSYNTHETICS- TABLE 213-2.2(A)

### CITY OF TORRANCE

DATE ISSUED

DEC 2012

### TYPICAL SECTION COLLECTOR AND ARTERIAL STREET

ROBERT J. BESTE  
PUBLIC WORKS DIRECTOR  
R.C.E. NO. 50737

*RB / RA*

STANDARD NO.

**T103**

SHEET 2 OF 2