

SANITARY SEWER GENERAL NOTES (CON'T)

14. TRENCH RESURFACING SHALL BE OF THE SAME TYPE AS THE EXISTING PAVEMENT, EXCEPT IF EXISTING PAVEMENT IS A.C. OVER P.C.C., RESURFACING MAY BE FULL-DEPTH A.C.

15. MANHOLE COVER SHALL BE CAST WITH THE WORDS "TORRANCE SEWER" FOR CITY MAINTAINED LINES AND "PRIVATE SEWER" FOR PRIVATELY MAINTAINED LINES.

16. ALL SEWER LINES CONSTRUCTED TO PUBLIC STANDARDS SHALL BE VITRIFIED CLAY PIPE (VCP). DUCTILE IRON PIPE MAY BE USED SUBJECT TO PRIOR WRITTEN APPROVAL FROM THE COMMUNITY DEVELOPMENT/PUBLIC WORKS DIRECTOR. ALL HOUSE CONNECTION LATERALS SHALL BE MINIMUM 6 INCH DIAMETER.

17. CONTRACTOR SHALL SET ALL MANHOLE FRAMES AND COVERS TO FINISHED GRADE.

18. CONCRETE ENCASEMENT SHALL BE REQUIRED FOR SEWER MAIN LINE AND HOUSE LATERALS WITH LESS THAN 3 FEET OF COVER.

19. THE CONTRACTOR SHALL MAKE AVAILABLE FOR THE INSPECTOR'S REVIEW, ON A DAILY BASIS, AS-BUILT DRAWINGS FOR WORK PERFORMED UP TO AND INCLUDING THE PREVIOUS DAY'S ACTIVITIES. WORK SHALL NOT BE CONSIDERED AS COMPLETE UNTIL AS-BUILT DRAWINGS ARE SUBMITTED TO AND ACCEPTED BY THE COMMUNITY DEVELOPMENT/PUBLIC WORKS DIRECTOR.


**CITY OF TORRANCE**

DATE ISSUED

19 FEB 2008

**SANITARY SEWER GENERAL NOTES**

ROBERT J. BESTE  
PUBLIC WORKS DIRECTOR  
R.C.E. NO. 50737



STANDARD NO.

**T200**

SHEET 2 OF 2

TT\T200