



1. BEDDING "A" SHALL BE COMPOSED OF EITHER SAND, NO. 3 OR NO. 4 CRUSHED ROCK OR GRAVEL PER STANDARD SPECIFICATIONS. OTHER GRANULAR MATERIAL WITH A SAND EQUIVALENT OF 30 OR GREATER MAY BE USED WHEN APPROVED BY THE COMMUNITY DEVELOPMENT/PUBLIC WORKS DIRECTOR.
2. BEDDING "B" SHALL BE COMPOSED OF SAND OR OTHER GRANULAR MATERIAL WITH A SAND EQUIVALENT OF 30 OR GREATER AS APPROVED BY THE COMMUNITY DEVELOPMENT/PUBLIC WORKS DIRECTOR AND SHALL CONFORM TO SECTION 306-1.2.1 OF THE STANDARD SPECIFICATIONS, EXCEPT BEDDING FOR PLASTIC PIPE SHOULD CONFORM TO SECTION 306-1.2.13.
3. BEDDING "B" SHALL BE COMPACTED TO A RELATIVE COMPACTION OF NOT LESS THAN 90 PERCENT UNLESS OTHERWISE SPECIFIED.
4. BEDDING "B" SHALL BE PLACED IN TWO OR MORE LIFTS FOR PIPES WITH AN O.D. GREATER THAN 60 INCHES.

CITY OF TORRANCE

DATE ISSUED	BEDDING FOR STORM DRAIN	STANDARD NO.
02 JUL 2008		T302
ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737		SHEET 1 OF 2

TT\T302