

5. BACKFILL SHALL BE PER SECTION 306-1.3 OF THE STANDARD SPECIFICATIONS.
6. WHERE THE COVER IS 8 FEET OR LESS, "W" MUST BE A MINIMUM OF 6 INCHES. WHERE THE COVER IS GREATER THAN 8 FEET, "W" MUST BE BETWEEN 6 AND 10 INCHES INCLUSIVE FOR PIPES UP TO AND INCLUDING 96 INCHES IN DIAMETER. FOR PIPES OVER 96 INCHES IN DIAMETER, "W" MUST BE BETWEEN 6 AND 12 INCHES INCLUSIVE.
7. "W" SHALL INCLUDE THE THICKNESS OF ANY SHORING.
8. SHORING SHALL BE A MINIMUM OF 6 INCHES FROM THE PIPE AT SPRINGLINE.

**CITY OF TORRANCE**

DATE ISSUED	<b>BEDDING FOR STORM DRAIN</b>	STANDARD NO.
02 JUL 2008		<b>T302</b>
ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737 		SHEET 2 OF 2

TT\T302