

GENERAL NOTES (CON'T)

14. FOR PARALLEL CONSTRUCTION ALL WATER LINES SHALL BE INSTALLED WITH A TWO FOOT (MIN.) CLEARANCE FROM EXISTING UTILITY LINES (GAS, TELEPHONE, CABLE, POWER...). A MINIMUM OF 12" CLEARANCE SHALL BE PROVIDED WHEN CROSSING UTILITY LINES.

15. NO PVC PIPE SHALL BE INSTALLED UPSTREAM OF THE INLET SIDE OF METERS OR DETECTOR CHECK VALVES.

16. CONTRACTOR SHALL MAKE AVAILABLE FOR THE PUBLIC WORKS INSPECTOR'S REVIEW, ON A DAILY BASIS, AS-BUILT DRAWINGS FOR WORK PERFORMED UP TO AND INCLUDING THE PREVIOUS DAY'S ACTIVITIES. WORK SHALL NOT BE CONSIDERED AS COMPLETE UNTIL AS-BUILTS ARE SUBMITTED TO AND ACCEPTED BY THE COMMUNITY DEVELOPMENT OR PUBLIC WORKS DIRECTOR.

17. TRENCHES CUT INTO AN EXISTING ROADWAY WITHIN THE PUBLIC RIGHTS OF WAY SHALL BE BACKFILLED AND PAVED AS PER CITY OF TORRANCE STANDARD T116.

18. TRENCH RESURFACING SHALL BE OF THE SAME TYPE AS THE EXISTING PAVEMENT, EXCEPT IF EXISTING PAVEMENT IS A.C. OVER P.C.C., RESURFACING MAY BE FULL-DEPTH A.C.

19. PIPE BEDDING SHALL CONFORM TO TORRANCE STANDARD DRAWING T701.

20. ALL FLANGE NUTS, BOLTS AND WASHERS SHALL BE 316 S.S. UNLESS OTHERWISE SHOWN.

21. ALL BURIED PIPE, VALVES, FITTING, ETC. SHALL BE WRAPPED IN 8 MIL. POLYETHYLENE.

CITY OF TORRANCE

DATE ISSUED	WATER GENERAL NOTES	STANDARD NO.
12 MAY 2008	ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737 	T700
		SHEET 2 OF 2

TT/T700