



NOTES:

1. SAND BEDDING SHALL CONFORM TO SECTIONS 200-1.5.3 AND 200-1.5.5 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (LATEST EDITION).
2. DENSIFICATION OF BEDDING SHALL BE ACCOMPLISHED IN CONFORMANCE WITH 306-1.2.1 OF THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (LATEST EDITION).
3. BEDDING SHALL BE COMPACTED TO 95% OF MAXIMUM DENSITY UNDER STRUCTURES AND 90% ELSEWHERE.

ACCOMPANYING STD.'S T700 AND T116

CITY OF TORRANCE

BEDDING FOR WATER PIPE

DATE ISSUED

JAN 2011

STANDARD NO.

T 701

ROBERT J. BESTE
PUBLIC WORKS DIRECTOR
R.C.E. NO. 50737

Handwritten signature: RJA / RJA

SHEET 1 OF 1

DV/EM/T701-1