



NOTES:

1. CORPORATION STOP SHALL BE INSTALLED ON THE MAIN DIRECTLY OPPOSITE THE LOCATION OF THE METER.
2. FOR 3/4" METER USE JONES BUSHING E128H
3. FOR SINGLE RESIDENTIAL HOMES, BUSINESSES, OR PRIVATE DEVELOPMENT, WITH LESS THAN 76 METERS, THE METERS SHALL BE SUPPLIED AND INSTALLED BY CITY AT REQUESTING PARTY'S EXPENSE.
4. FOR CAPITAL IMPROVEMENT PROJECTS, AND DEVELOPMENT PROJECTS WITH 76 METERS OR MORE THE METERS SHALL BE SUPPLIED AND INSTALLED BY CONTRACTOR AT CONTRACTOR'S EXPENSE

ACCOMPANYING STD.'S T700, T701, T702 AND T116

ITEM	DESCRIPTION	SIZE
①	SERVICE SADDLE—DOUBLE STRAP—BRONZE JONES 979, MCDONALD 3825, MUELLER BR2B, CC THREAD	MAIN SIZE X 1"
②	CORPORATION STOP—JONES E1930, FORD FB600—4NL, MUELLER B25000N MCDONALD 74701B	1"
③	COPPER TUBING—TYPE "K" SOFT	1"
④	ANGLE METER STOP—JONES E1964W, FORD BA23—444WNL, MUELLER B24255N MCDONALD 74620	1" (SEE NOTE 2)
⑤	NEPTUNE T-10 WATER METER, E-CODER) R900i v4 CU.FT. REGISTER	3/4" SL OR 1"
⑥	METER SWIVEL COUPLING — JONES E130, MCDONALD 74620 — FORD C38-23-2.5NL (3/4") — FORD C38-44-2.625NL (1")	3/4", 1"
⑦	METER BOX W/COVER —ARMORCAST	BOX#33 (A6000486) COVER #33 (A6000483-T)
⑧	COPPER FLARE NUT	1"
⑨	NEOPRENE FULL FACE GASKET	

CITY OF TORRANCE

DATE ISSUED

Nov 2015

**TYPICAL 3/4" OR 1" METER
INSTALLATION WITH 1" SERVICE LINE**

ROBERT J. BESTE
PUBLIC WORKS DIRECTOR
R.C.E. NO. 50737

STANDARD NO.

T 703

SHEET 1 OF 1