



NOTE:

1. CORPORATION STOP SHALL BE INSTALLED ON THE MAIN DIRECTLY OPPOSITE THE LOCATION OF THE METER.
2. NUTS AND BOLTS FOR CONNECTIONS TO METER SHALL BE STAINLESS STEEL.
3. METER AND BALL VALVE ((9)) SHALL BE SUPPLIED AND INSTALLED BY TMWD AT REQUESTING PARTY'S EXPENSE. (NOT SUPPLIED BY TMWD FOR CAPITAL IMPROVEMENT PROJECTS).

NEPTUNE MODEL	SIZE	COVER	TRAFFIC COVER	BOX
T-10 DISC	1 1/2"	A6001643, #66	A6001947T, #66	A6001640 PCX12, #66
	2"	A6001643, #66	A6001947T, #66	A6001640 PCX12, #66
HI-PERFORMANCE TURBINE W/STRAINER (NOT SHOWN)	1 1/2"	A6001643, #66	A6001947T, #66	A6001640 PCX12, #66
	2"	A6001643, #66	A6001947T, #66	A6001640 PCX12, #66
TRU FLO COMPOUND W/ SEPARATE STRAINER (NOT SHOWN)	2"	A6001975, #67	A6001975T, #67	A6001974 PCX12, #67

ACCOMPANYING STD.'S T700, T701, T702 AND T116.

ITEM	DESCRIPTION	SIZE
①	SERVICE SADDLE-DOUBLE STRAP-BRONZE JONES 979, MCDONALD 3825, MUELLER BR2B, CC THREAD	MAIN SIZE X 2"
②	CORPORATION STOP-JONES E1930, FORD FB600-4NL, MUELLER B25000N MCDONALD 74701B	2"
③	45° ELBOW-COPPER TO COPPER SJxSJ	2"
④	COPPER TUBING-TYPE "K" SOFT	2"
⑤	90° ELBOW-SJXSJ	2"
⑥	ANGLE METEER STOP-JONES E1975W, FORD BFA43-777WNL,	2"
⑦	METER BOX W/ COVER - ARMORCAST	SEE TABLE
⑧	NEPTUNE WATER METER, E-CODER)R900i v4 CU. FT. REGISTER (TYPE TO BE DETERMINED BY TMWD)	SEE TABLE
⑨	BALL VALVE-JONES E1913W, FLGxFIP, -FORD BF13-777WNL OR 666WNL, W/HB67S HANDLE, FLGxFIP	1-1/2" OR 2"
⑩	NEOPRENE FULL FACE GASKET	1-1/2" OR 2"
⑪	PACK JOINT	

CITY OF TORRANCE

DATE ISSUED	TYPICAL 1-1/2" OR 2" METER INSTALLATION WITH 2" SERVICE LINE	STANDARD NO.
NOV 2015	ROBERT J. BESTE PUBLIC WORKS DIRECTOR R.C.E. NO. 50737 	T 704
		SHEET 1 OF 1

X:\ENG\VPrescd\Water Standards\T704.dwg 11/19/15 07:43 vprasad