

ASSEMBLY SHALL BE TESTED BY A CITY APPROVED TESTER CERTIFIED BY THE LOS ANGELES COUNTY DEPT. OF PUBLIC HEALTH. THE DEVELOPER/OWNER IS RESPONSIBLE FOR THE COST OF TESTING THE ASSEMBLY.

ITEM	DESCRIPTION	SIZE
1	D.I. WATER PIPE (CLASS 350)	
2	90°, D.I. ELBOW, MJ X FLG, CLS 350	SERVICE SIZE
3	D.I. SPOOL, CLS 350 (BOTH ENDS SHALL BE FLANGED) (UNI-FLANGE SHALL NOT BE USED)	
4	90°, D.I. ELBOW, FLG. CLS 350.	
(5)	REDUCED PRESSURE PRINCIPLE ASSEMBLY	
6	3/4" COPPER BY-PASS ASSEMBLY (NEPTUNE WATER METER, E-CODER) R900i v4 CUBIC FEET REGISTER). (3)-3/4" FIP BALL VALVES W/LOCKWING (JONES E1908, FORD B13-332WNL)	5/8"
7	VALVE BOX ASSEMBLY PER T712	
8	MUELLER NO.A2362-16 GATE VALVE, MJxFLG, W/EVERDUR STEM & SS 316 FASTENERS W/2" NUT & NRS OPENING CCW.	
9	M.J. x FLG. DUCTILE IRON TEE OR TAPPING SLEEVE (MUELLER: H615, H616 OR H619)	

	CITY OF TORRANCE	
DATE ISSUED	REDUCED PRESSURE PRINCIPLE DETECTOR	STANDARD NO.
NOV 2015	ASSEMBLY > 2"	T 711
	ROBERT J. BESTE PUBLIC WORKS DIRECTOR R C F NO 50737	SHEET 1 OF 1

Standords\T711.dwg asad\Water