

BASIC SEPARATION STANDARDS

1. PARALLEL CONSTRUCTION: THE HORIZONTAL DISTANCE BETWEEN PRESSURE DOMESTIC WATER AND RECLAIMED WATER MAINS AND SEWER LINES SHALL BE AT LEAST 10 FEET.
2. PERPENDICULAR CONSTRUCTION (CROSSING): PRESSURE WATER MAINS SHALL BE AT LEAST ONE FOOT ABOVE SANITARY SEWER AND RECLAIMED WATER LINES WHERE THESE LINES MUST CROSS.
3. SPECIAL PROVISIONS: ALTERNATE CONSTRUCTION CRITERIA WHERE THE BASIC SEPARATION STANDARDS CANNOT BE ATTAINED ARE SHOWN BELOW:

ZONE	WATER CONSTRUCTION (EXISTING SEWER)
B	1) CLASS 350 D.I.P. WATER MAIN. 2) APPROVED ALTERNATES.
C/D	1) CLASS 350 D.I.P. WATER MAIN W/NO JOINT 2) STEEL CASING PER STD. T715 3) APPROVED ALTERNATES.
A	NO CONSTRUCTION WITHOUT APPROVAL OF WATER DIVISION AND DEPARTMENT OF PUBLIC HEALTH.
P	CONSTRUCTION WITHIN THIS AREA PROHIBITED.

CITY OF TORRANCE

**WATER AND SEWER
SEPARATION REQUIREMENTS**

ROBERT J. BESTE
PUBLIC WORKS DIRECTOR
R.C.E. NO. 50737

TCB / BJA

STANDARD NO.

T 714

SHEET 2 OF 2

DATE ISSUED

JAN 2011