



* SEE T722 FOR DIMENSIONS

ITEM	DESCRIPTION
①	6",8", x 4" D.I. FLG. TEE
②	6",8",10" MUELLER A2362-6 GV W/EVERDUR STEMS, HANDWHEEL & NRS OPENING CCW, W/LOCK & CHAIN
③	6",8",10" SCHLUMBERGER NEPTUNE STRAINER
④	6",8",10" SCHLUMBERGER NEPTUNE METER W/AUTOMATIC BILLING & READING MINI PIT RECEPTACLE W/25' WIRE, INSTALLED IN VAULT COVER NEAR CORNER & HINGE, CLEAR OF OBSTRUCTIONS.
⑤	TEST PORT (OMIT IF METER HAS TEST PORT) 6",8",10" x 4" D.I. FLG TEE, 6",8",10" BLIND FLANGE x 2" FIP, 2" BRASS NIPPLE, 2" FIP LOCKWING BALL VALVE W/2" MIP PLUG (BALL VALVE FORD B11-777W OR JONES J-1900W)
⑥	BROOKS PRODUCTS BOX (SEE STD. NO. T722)
⑦	4" D.I. 90° FLG. ELBOW
⑧	4" MUELLER A2362-6 FLG. GV W/EVERDUR STEMS, HANDWHEEL & NRS OPENING CCW, W/LOCK & CHAIN
⑨	4" D.I. PIPE, FLG x PE
⑩	SOLID SLEEVE TYPE COUPLER, RJ x RJ
⑪	6", 8", 10" x 24" D.I. FLG. SPOOL

ACCOMPANYING STD T700, T712, T713, T722 AND T723.

CITY OF TORRANCE - ENGINEERING DEPARTMENT

DATE ISSUED
NOV 2015

TYPICAL UNDERGROUND ASSEMBLY FOR 6" - 8"
"NEPTUNE" METER W/BYPASS, 6" - 10" W/O BYPASS

ROBERT J. BESTE
PUBLIC WORKS DIRECTOR
R.C.E. NO. 50737

RJB

STANDARD NO.

T720-2

SHEET 1 OF 1