

## 3" AND 4" METER IN VAULT

METER TYPE	3" COMPOUND		4" COMPOUND		3" TURBINE		4" TURBINE	
	YES	NO	YES	NO	YES	NO	YES	NO
VAULT #	W-466*	W-44*	847**	W-45*	847**	W-45*	848**	W-466*
WIDTH	48"	48"	45 1/2"	48"	45 1/2"	48"	45 1/2"	48"
LENGTH	78"	48"	81 1/2"	60"	81 1/2"	60"	93 1/2"	78"
DEPTH	42"	39"	48"	45"	48"	39"	48"	39"
A	4 5/8"	-	2 1/2"	-	3 3/8"	-	2 1/2"	-
B	19 3/8"	24"	20 1/4"	24"	19 3/8"	24"	20 1/4"	24"
e	10 1/2"	4 1/8"	4 1/2"	6 7/8"	6 3/4"	7 1/8"	7"	12 3/8"
h	35 1/4"	35 1/4"	36 1/2"	36 1/2"	34 1/4"	34 1/4"	34 3/8"	34 3/8"

## 6" - 10" METER IN VAULT

METER TYPE	6" COMPOUND		6" TURBINE		8" TURBINE		10" TURBINE	
	YES	NO	YES	NO	YES	NO	YES	NO
VAULT #	**859	*W-466	**8510	**847	**8511	**848	**869	*W-4686
WIDTH	57 1/2"	48"	57 1/2"	45 1/2"	57 1/2"	45 1/2"	69 1/2"	54"
LENGTH	105 1/2"	78"	117 1/2"	81 1/2"	129 1/2"	93 1/2"	105 1/2"	102"
DEPTH	48"	45"	48"	42"	48"	48"	48"	45"
A	5 1/4"	-	5 1/4"	-	6 1/4"	-	6 7/16"	-
B	23 1/2"	24"	23 1/2"	22 3/4"	22 1/2"	22 3/4"	28 5/16"	27"
C	9 1/4"	-	9 1/4"	-	9 1/4"	-	11 1/16"	-
D	19 1/2"	-	19 1/2"	-	19 1/2"	-	23 11/16"	-
e	9 1/4"	11 5/8"	10 1/4"	8 3/8"	10 3/4"	10 7/8"	7 7/8"	6 1/8"
h	38 1/2"	38 1/2"	35 1/2"	35 1/2"	36 3/4"	36 3/4"	35 1/2"	35 1/2"

VAULT IS TO BE PROVIDED WITH ALUMINUM HINGED SPRING LOADED COVER. PROVIDE A 1 1/2" Ø HOLE AT CORNER OF COVER CLOSEST TO THE HINGE.

\* JENSEN PRECAST                      \*\* BROOKS PRODUCTS, INC.

ACCOMPANYING STD'S T719, T720, T721

### CITY OF TORRANCE - ENGINEERING DEPARTMENT

## UNDERGROUND METER VAULT REQUIREMENTS

STANDARD NO.

**T722-2**

SHEET 1 OF 1

RICHARD W. BURTT  
ENGINEERING DIRECTOR  
R.C.E. NO. 32862



EM/T722-2

DATE ISSUED  
23 JUL 2002