



NOTE:

1. VALVE STEM EXTENSION SHALL BE PROVIDED WHERE DEPTH TO OPERATING NUT EXCEEDS 4'-0".
2. FACE OF CURB SHALL BE NOTCHED WITH "V " & PAINTED PURPLE TO DENOTE VALVE LOCATION.
3. PAINTING OF METER BOX LID AND VALVES AND VALVE TAGS SHALL BE PER THE SPECIFICATIONS.

CITY OF TORRANCE - ENGINEERING DEPARTMENT

DATE ISSUED	RECLAIMED WATER VALVE BOX ASSEMBLY	STANDARD NO.
28 FEB 1997	RICHARD W. BURTT ENGINEERING DIRECTOR R.C.E. NO. 32862 	T806-0
		SHEET 1 OF 1