




TORRANCE POLICE DEPARTMENT

EXCELLENCE THROUGH TEAMWORK



FIRE LANE IDENTIFICATION

Fire Lane - No Stopping Sign (*Mandatory*)



Notes:

- Signs shall be in accordance with Caltrans/FHWA standard [R26F]
- Signs shall include appropriate CVC section [22500.1]
- Sign shall be adjacent/visible from the designated fire lane
- Spaced at maximum intervals of 50ft on center or fraction thereof
- Signs shall be mounted 7ft above grade
- Lettering shall not be less than 1" in height

AND

Fire Lane - Curb Painting (*with above sign*)



Notes:

- Entire curb shall be painted red [two coats]
- White lettering - "NO STOPPING - FIRE LANE" [two coats]
- Lettering height - minimum of 4 inches
- Lettering to be on top of designated curbing
- Spaced at maximum intervals of 25ft on center of fraction thereof

OR

Fire Lane - Striping, No Curb (*with above sign*)

FIRE LANE - NO STOPPING

Notes:

- Minimum width of this red stripe shall be 8 inches [two coats]
- White lettering - "NO STOPPING - FIRE LANE" [two coats]
- Lettering height - minimum of 6 inches
- Spaced at maximum intervals of 25ft on center or fraction thereof