

ADDENDUM # 1

**CITY OF TORRANCE
3031 Torrance Blvd.
Torrance, CA 90503**

RFP NO. B2020-04

RFP for HVAC Filter Replacement Services at Various City Buildings

ADDENDUM # 1- Issued 2/20/20

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT RFP:

Proposal Due Date remains on **Monday, February 24, 2020 by 3:00 PM** in the Office of the City Clerk, 3031 Torrance Blvd., Torrance, CA 90503.

Below are questions raised during the proposal preparation period with answers in bold.

1. Question regarding gun range air filters. Does the gun range allow lead ammo to be used? If yes, are there special procedures in place to handle/change/dispose air filters in gun range?

The City of Torrance gun range uses “clean Fire” ammunition. There are no special procedures required to handle/change/dispose the air filters in the gun range since there is not enough lead to trigger any special requirements.

Please return this addendum with your bid proposal.
I hereby acknowledge receipt of this addendum.

Name of Company

Address

City State Zip Code