

**ADDENDUM # 1**

**CITY OF TORRANCE  
3031 Torrance Blvd.  
Torrance, CA 90503**

**BID NO. B2022-11**

---

**Bid for Fire Alarm Detection System at Greenwood Center**

---

ADDENDUM # 1- Issued 03/28/2022

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

CLARIFY: The Bid Due Date remains on **Wednesday, April 13, 2022 by 3:00 PM** in the Office of the City Clerk, 3031 Torrance Blvd., Torrance, CA 90503.

CLARIFY: The contractor may provide an alternate design solution to the attic heat detectors using a UL listed, CSFM approved heat trace wire, or similar. Attic detectors are required per NFPA 72 code for non-sprinklered buildings.

CLARIFY: Onsite work is to begin Monday, August 15, 2022. The working hours are 7:30 a.m. to 6:00 p.m. with no noisy work before 7:30 a.m. per the TMC or between the hours of 12:00 – 2:30pm.

Please return this addendum with your bid proposal. Failure to acknowledge addenda and submit it with your proposal may render the proposal non-responsive and cause it to be rejected. I hereby acknowledge receipt of this addendum.

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
City            State            Zip Code