

**ADDENDUM # 1**

**CITY OF TORRANCE  
3031 Torrance Blvd.  
Torrance, CA 90503**

**BID NO. B2022-16**

---

**Bid for Fire Station No. 4 Renovation**

---

ADDENDUM # 1- Issued 04/06/2022

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

CLARIFY: The Bid Due Date remains on **Wednesday, April 13, 2022 by 3:00 PM** in the Office of the City Clerk, 3031 Torrance Blvd., Torrance, CA 90503.

Below are questions raised during the bid preparation period with answers in bold:

1. Are there any door hardware specifications?

**Please see Sheet A8.1 Door Schedule / Door Types / Notes 2, 4 & 6 for kick plates, lever hardware & closers in locations as shown. Also provide the following:**

- **Hinges in satin chrome**
- **Smoke seals & gaskets as required at rated doors per door schedule**
- **Thresholds to suit sill conditions**

**Manufacturers:**

**Kickplates:** Trimco 10" high Stainless Steel

**Locksets:** Yale PB Series Satin Chrome

**Closers:** LCN 4040XP Satin Chrome

**Hinges:** Hagar AB 850 4.5X4.5 Satin Chrome

**Thresholds:** Pemco Satin Anodized Aluminum

**Finish Hardware Schedule to be submitted for review during construction phase.**

Please return this addendum with your bid proposal.  
Failure to acknowledge addenda and submit it with your proposal may render the proposal non-responsive and cause it to be rejected. I hereby acknowledge receipt of this addendum.

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
City            State            Zip Code